

## CONNECTING DATA TO DECISIONS

Case Studies - Volume 2

---

Linking Total Transformer Monitoring & Actionable Information  
to Drive Business Value for Utilities



camlin **energy**

# CONTENTS

---

## Introduction

Transforming Data to Drive Decision making  
A Holistic Transformer Monitoring Approach

## Case Study 5

Italian Transmission Utility

## Case Study 6

Italian Distribution Company

## Case Study 7

Canadian Transmission Utility

## Case Study 8

European Distribution Company

Connecting Data to Decisions

## TRANSFORMING DATA TO DRIVE DECISION MAKING

---


Power transformers are integral to the flow of energy and dynamic communication and could be viewed as the nerve centre in the era of digitalization of energy systems. However, environmental and operational factors can affect the health of an aged transformer fleet and reduce the capabilities and readiness for the technological change.

The use of a more holistic and integrated approach to transformer monitoring can significantly help to optimize maintenance and mitigate risk. Holistic means the treatment of the whole transformer, taking into account operational data, environmental data, external factors and previous experiences, rather than just a single diagnostic parameter such as DGA. The chances of identifying the failure mode or defect can dramatically increase, allowing asset owners to understand their risk and ultimately make prompt and better-informed decisions.


The following case studies demonstrate successful examples when the utility was able to plan preventive actions and maintenance thanks to the study of the correlation of two or more parameters.

## TOTUS MONITORING


---



TOTUS G9




TOTUS G5



INTEGO

## A holistic transformer monitoring approach



\* Focus area for future development

**Only when monitoring all the key components and parameters, in synergy, can the factors of health, risk and reliability be better understood.**

## ITALIAN TRANSMISSION UTILITY



### Details

Floating corona shield cone surrounding HV lead in phase V.



### Evidence

HEE persistence > 6%, PD phase V, critical gas levels.

The TOTUS installed allowed for real time, continuous monitoring of the asset and detected fluctuations in PD occurring for several hours in a day and then remaining silent for weeks, showing very high energy (> 20 V, > 80nC).

This highlighted the existence of a lose/broken grounding connection in the corona shield cone immersed in the transformer tank, enabling the transmission utility to apply a proper action flow, leading to the failure prevention and optimization of the maintenance plan.





Figure 1: High Energy Event evidences, Phase V

## ITALIAN DISTRIBUTION COMPANY



### Details

Protrusion on cap. stress ring above HV winding, phase U.




### Evidence

Medium PD activity persistence > 80%.  
Located in phase U.

Manufactured in 2010, a suspect Hydrogen and Acetylene concentration was noticed in the transformer after an Oil Lab evaluation in 2011. Transformer OEM supposed stray gassing phenomena. The INTEGO TM was installed by the Utility and confirmed that cause was not stray gassing but a PD defect in one of the phases (phase U). Sporadic PD activities can where also present in phase W.

Figure 1. PD stress ring evidences, Phase U



The transformer was inspected, evidences reported in Figure 1. Show the INTEGO TM provided an effective diagnosis and location thanks to the Camlin PD Triangle.

Furthermore, the INTEGO TM allowed the Distribution company to reinforce their thesis and provided proof to the OEM of the absence of stray gassing phenomena.

## CANADIAN TRANSMISSION UTILITY



### Details

Partial breakdown within bushing control layers.



### Evidence

Sudden capacitance relative increase (2.8%) and PD in bushing (phase H2) detected by TOTUS TTM.

TOTUS TTM monitoring unit was installed in October 2017 on a 504 MVA AT provided with >30-year-old bushings (1980).

Catastrophic faults have been experienced by the utility on same bushings.

On April 2018, a sudden capacitance change from Phase H2 was detected.


Deviation recorded (> 2 %) was consistent with a short circuit between layers for a 345 kV bushing. Furthermore, the evidence was confirmed by Offline tests.

The TOTUS TTM played a vital role, successfully highlighting the deviation and preventing a high risk event.

The Canadian utility was able to highlight a sudden capacitance increase within the Autotransformer H2 bushing.

In addition, an effective Condition Based Maintenance was enabled, which allowed the utility to minimize the overall costs of ownership and maintenance.

Figure 1: Sudden Capacitance increase, Phase H2



## The TOTUS TTM played a vital role, successfully highlighting the deviation and preventing a high risk event.

From an asset management point of view, the increasing does not represent an immediate risk factor for the Bushing provided that future records do not highlight further sudden changes in the Capacitances.

As a result, the transformer was left operational until the Offline measurement session.


It must be highlighted that the Offline test was conducted 38 days after the event (28th of May) leading to an extremely successful Condition Based Maintenance with an extremely important impact on economic losses due to an extended outage.

Bushing Offline Tests confirmed the Capacitance Increasing!

Straight interpretations of the results were not immediate, meaningful conclusions therefore took time.

NOTE: nameplate has been determined in the '70s and the accuracy may not be same as nowadays.

	NP	16th Oct 2017	28th May 2018
Phase H1	428 pF	419.078 pF	423.785 pF
Phase H2	415 pF	415.472 pF	423.94 pF
Phase H3	419 pF	410.956 pF	415.376 pF
Phase X1	339 pF	338.054 pF	339.888 pF
Phase X2	340 pF	339.498 pF	341.884 pF
Phase X3	339 pF	340.043 pF	342.159 pF




For the above reasons, Camlin evaluated the relative deviation between the phases and the results compared between the two measurement sessions:

Relative HV Bushing changes [pF]

16/10/2017


28/05/2018



Relative LV Bushing changes [pF]

16/10/2017

28/05/2018



## EUROPEAN DISTRIBUTION COMPANY



### Details

Monitoring as a control system for corrective actions.



### Evidence

Oil gassing highlighted (H<sub>2</sub>). suspect was an oil sharing between LTC and main tank. corrective action was planned and TOTUS DGA used to monitor and confirm the effectiveness of the mitigation.


A TOTUS DGA monitoring unit was installed in December 2017 on a 31.5 MVA transformer.

Historical DGA Lab analysis highlighted Hydrogen increasing over time and the utility, following a preliminary investigation, suspected the gassing was caused by the LTC tank which shared oil with main tank.

Follow-up action to resolve the case was determined and the final decision was to operate the transformer with a fixed tap position. This would avoid the gas formation and the expectation is a progressive decreasing of the ppm absolute concentration.

The TOTUS DGA tracked the readings to ensure no further gas creation. This enabled the utility to keep the Transformer in service longer, enabling an effective life extension.

Figure 1: DGA Behavior from Installation date.




## ACTIONABLE INFORMATION CREATING BUSINESS VALUE

1



### Generate the Data

- Detect Anomalies, alarm triggered



2




### Transform Data to Information

- Correlate the anomalies
- Determine possible failure mode



3



### Apply Knowledge to Information

- Combine parameters into condition index to represent transform
- Confirm failure mode to trigger best offline test
- Determine prescriptive actions


Activity required	Asset ID	Substation	Condition Index	Comments
Test	TR27	551	4.56	Off-line Capacitance Test on Bushing A to be planned within one month
Test	TR32	552	4.23	Electrical Tests required (PD, Winding resistance, insulation resistance)
Test	TR3	554	3.82	Oil regeneration and leakage repair
Test	TR23	551	3.59	Oil regeneration
Test	TR29	553	3.34	Oil regeneration
Test	TR3	551	3.32	Schedule IR camera for bad contacts
Test	TR4	553	3.31	Schedule Visual inspection for oil leakage
Test	TR25	554	3.31	
Test	TR26	554	3.44	
Test	TR25	554	3.44	
Test	TR26	554	3.37	
Test	TR27	554	2.3	
Test	TR25	554	2.38	
Test	TR4	553	2.04	
Test	TR5	553	1.71	
Test	TR28	554	1.65	

4



### Apply Wisdom to Drive Decision Making

- Understand risk to operations
- Budgets, environmental issues
- Correlate with external parameters
- Alignment with maintenance planning



- + + + + +  
- + + + + +  
- + + + + +  
+ + + + + + +  
+ + + + + + +  
+ + + + + + +

**Camlin Energy**  
31 Ferguson Drive, Lisburn, BT28 2EX, Northern  
Ireland  
Email: [mail@camlingroup.com](mailto:mail@camlingroup.com)  
Tel: +44(0) 2892 626 989

[camlingroup.com](http://camlingroup.com)



**camlin energy**